



## Riassunto rapporti analisi 2015

DATA PRELIEVI	23.03.		14.06.		22.09.		16.12.		Valore tolleranza
	Paese	Nadro	Paese	Nadro	Paese	Nadro	Paese	Nadro	
<b>ANALISI MICROBIOLOGICA</b>									
Germi aerobi mesofili	0 UFC/ml	2 UFC/ml	0 UFC/ml	0 UFC/ml	15 UFC/ml	12 UFC/ml	6 UFC/ml	1 UFC/ml	300 UFC/ml
E.coli	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml
Enterococchi	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml	0 UFC/100 ml
<b>ANALISI FISICO CHIMICA</b>									
pH	7.3	7.35	7.15	7.07	7.19	7.24	7.23	7.2	6 - 9.2
Conduttività	57 mcS/cm	90 mcS/cm	66 mcS/cm	97 mcS/cm	67 mcS/cm	93 mcS/cm	60 mcS/cm	92 mcS/cm	-
Temperatura	8.7 °C	8.5 °C	12.8 °C	12.8 °C	15.9 °C	17.1 °C	9.1 °C	9.6 °C	-
Durezza totale	0.2 mmol/l	0.4 mmol/l	-	-					-
Alcalinità	0.49 mmol/l	0.67 mmol/l	-	-					-
Calcio	< 10 mg/l	12 mg/l	-	-					-
Magnesio	< 5 mg/l	< 5 mg/l	-	-					-
Ferro in soluzione	< 0.1 mg/l	< 0.1 mg/l	-	-					0.3 mg/l
Nitriti	< 0.02 mg/l	< 0.02 mg/l	-	-					0.1 mg/l
Nitrati	3.2 mg/l	5.7 mg/l	-	-					40 mg/l
Cloruri	0.9 mg/l	2.8 mg/l	-	-					200 mg/l
Solfati	< 10 mg/l	< 10 mg/l	-	-					-
Fosfati (P)	< 0.2 mg/l	< 0.2 mg/l	-	-					1 mg/l
Silicati (SiO2)	9.3 mg/l	9.36 mg/l	-	-					10 mg/l
Ossidabilità KMnO4	3.35 mg/l	1.75 mg/l	-	-					6 mg/l